Display energy certificate (DEC)

HM Government

Queen Mary University of London
WOLFSON BUILDING
Charterhouse Square Campus
Queen Mary University of London
Charterhouse Square
LONDON
EC1M 6BQ

Operational rating

G

Certificate number:	9097-7962-6188-0473-9524
Valid until:	29 November 2022
Total useful floor area:	2042 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.



This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	300.56	245.44
Typical energy use (kWh/m2/year)	80	231.6
Energy from renewables	0.0%	0.0%

Previous operational ratings

Date	Operational rating
November 2021	239 | G
November 2020	248 | G
November 2019	326 | G

Total carbon dioxide (CO2) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.

Date	Electricity	Heating	Renewables
November 2021	338	97	0
November 2020	343	92	0
November 2019	381	192	0

Assessment details

Assessor's name	Simon Chandler
Employer/Trading name	1st For Energy
Employer/Trading address	Gillespie House, 12 Chapel St, Dunfermline, Fife. KY12 7AW
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Stroma Certification Ltd
Issue date	23 November 2021
Nominated date	30 November 2021